

TGTRANSCO Transmission Losses for the month of May-2024

EBC Data

| | | INPUT | OUTPUT | | | |
|--|--|--|---------------------|----------------|-------------|--|
| | | NET ENERGY in MU | DISCOM | MU | | |
| TGGENCO | TOTAL | 2150.88 | | | | |
| | TSGENCO-THERMAL | 2152.16 | TGSPDCL | 4493.57 | | |
| | TSGENCO-HYDEL | -1.28 | TGNPDCL | 1350.34 | | |
| C.T.U | | | Total Discom | 5843.91 | | |
| | CTU (Injection at TS-Periphery) | 2488.02 | | | | |
| CPPs | TOTAL | 173.90 | | | | |
| | 132kv Laxmi Tulasi | 0.00 | | | | |
| | 132 kV Orient Cement | 0.44 | | | | |
| | 220KV Navabharat Energy India Ltd (NBEIL)-I | 47.67 | | | | |
| | 220KV Navabharat Energy India Ltd (NBEIL)-II | 47.56 | | | | |
| | 132KV Penna Power-I | 0.00 | | | | |
| | 132KV Penna Power-II | 0.00 | | | | |
| | 132KV Deccan Cements | 0.00 | | | | |
| | 132 kV Madhucon | 0.00 | | | | |
| | 132kv SCCL 30MW Solar Plant (Manuguru) | 4.22 | | | | |
| | 220 kV Heavy Water Plant#1 | 0.00 | | | | |
| | 220 kV Heavy Water Plant#2 | 2.54 | | | | |
| | 132kv PSR Green Power Proj. Pvt. Ltd. | 0.00 | | | | |
| | 220KV RFCL | 0.00 | | | | |
| | 132 kV Kesoram | 0.00 | | | | |
| | 132 kV Sitapuram Power Limited | 1.56 | | | | |
| | 132 kV Anjaini Port Land Cement | 0.00 | | | | |
| | 132kv SCCL 37 MW Solar Plant (Sitharampatnam) | 5.72 | | | | |
| | 132 kV Sitaramapatnam - NBVL (NBFA)#1 | 28.38 | | | | |
| | 132 kV Sitaramapatnam - NBVL (NBFA)#2 | 27.80 | | | | |
| | 132 kV Sitaramapatnam - BPBL | 0.09 | | | | |
| | 132KV Shalivahana(MSW) Green Energy Ltd., | 0.00 | | | | |
| | 132kv Krishnaveni Sugars Ltd | 0.00 | | | | |
| | 132 kV My Home Industries Limited | 0.24 | | | | |
| | 132 kV ICL (Rassi Cements) | 0.00 | | | | |
| | 132 kV Bharat Electronics Ltd. (solar) | 2.13 | | | | |
| | 132kv SCCL Solar Power Plant (Yellandu) | 5.55 | | | | |
| | Non-Conventional (132 & 220 kV PDs) | Total | 467.07 | | | |
| | | ACME Medak Solar energy Pvt. Ltd. | 8.24 | | | |
| | | ACME Nizamabad Solar Energy Pvt. Ltd | 9.14 | | | |
| | | ACME PV Powertech Pvt. Ltd. (Sadasivpet) | 9.10 | | | |
| | | ACME Rangareddy Solar Power | 5.11 | | | |
| | | ACME Solar Power Tech. Pvt. Ltd. (Bhongir) | 9.52 | | | |
| | | Azure Power India Pvt. Ltd. (solar) | 17.49 | | | |
| Clean Hero Wind Power | | 4.69 | | | | |
| Clean Solar Power (Chittradurga) Pvt. Ltd | | 6.93 | | | | |
| Clean solar | | 4.84 | | | | |
| Dayakara Solar (P) Ltd. | | 5.29 | | | | |
| Dinakar Solar | | 4.82 | | | | |
| Divine Solren Pvt. Ltd. | | 8.82 | | | | |
| Dundigal Waste 2 Energy Power Plant | | 8.77 | | | | |
| Energon Soleq Solar (Sadasivapet) | | 8.83 | | | | |
| Enrich (Solar) | | 7.87 | | | | |
| G.S.R.Sugars Pvt Ltd | | -0.06 | | | | |
| Ganapathi Sugars Ltd. | | -0.06 | | | | |
| Grahati Solar | | 9.18 | | | | |
| Hyderabad MSW Energy Solutions PVT LTD | | 11.40 | | | | |
| Jilesh Power Pvt. Ltd (Solar) | | 9.06 | | | | |
| Kakatiya Cement & Sugar Industries Ltd. | | -0.11 | | | | |
| Karvy Solar Pvt. Ltd. (Sadasivapet) | | 3.39 | | | | |
| Karvy solar (Mandamarry) | | 8.18 | | | | |
| My Home Power Ltd. (NGPL) | | 0.00 | | | | |
| Mytrah Aakash Power Pvt.,Ltd. | | 9.04 | | | | |
| Mytrah Agriya Power Pvt. Ltd. (Solar) | | 9.07 | | | | |
| Mytrah Agriya Power Pvt. Ltd. (solar) (Kamareddy) | | 9.74 | | | | |
| Mytrah Vayu (Godavari) Pvt. Ltd. (Wind) | | 17.28 | | | | |
| NEO Solren Pvt. Ltd. (solar) | | 7.37 | | | | |
| NTPC Solar power plant (10MW) | | 0.90 | | | | |
| Nizam Deccan Sugars Ltd | | 0.00 | | | | |
| Param Pujya Solar Farms Ltd. Plant-I | | 9.77 | | | | |
| Param Pujya Solar Farms Ltd. Plant-II | | 11.44 | | | | |
| Polepally Solar Park | | 4.04 | | | | |
| Prathamesh solar farms Ltd. | | 9.58 | | | | |
| RDF Power Projects Pvt. Ltd. | | 0.00 | | | | |
| Renew Mega Solar Pvt.Ltd | | 9.57 | | | | |
| Renew Saurshakthi Pvt. Ltd. | | 5.89 | | | | |
| Renew Solar Energy Pvt. Ltd. 220kV | | 28.19 | | | | |
| Renew Solar Plant (Mdk. Dist.) | | 3.92 | | | | |
| Renew Solar Pvt Ltd. (Minpur) | | 12.58 | | | | |
| Renew Wind TN2 Solar | | 18.77 | | | | |
| Renue Akshay Solar Plant | | 16.47 | | | | |
| SLS Power Corp. Ltd. (Minihydel) 132KV | | 0.34 | | | | |
| SUZLON Energy Ltd. | | 20.81 | | | | |
| Shravana Power Projects Pvt. Ltd. | | -0.02 | | | | |
| Sky Power Southeast Asia III Ltd (Previously Sunshakthi solar) | | 10.18 | | | | |
| Sunborne Energy Tech. (P) Ltd. (Solar) | | 6.53 | | | | |
| Sunworld Solar Power Pvt. Ltd. | | 5.48 | | | | |
| Suprasanna Solar | | 3.42 | | | | |
| Suraj Kiran Solar Technologies (Mdk) | | 9.82 | | | | |
| Suraj Kiran solar (Nlg) | | 9.76 | | | | |
| Suryoday Energy Pvt. Ltd. (Shapoorji Pallonji)(Solar) | | 6.17 | | | | |
| Transform Sun Energy 220kV | | 16.55 | | | | |
| Ujjvalatejas Solaire Urja Pvt. Ltd. (Solar) | 3.46 | | | | | |
| Vena Energy Solar Pvt Ltd (Previously Energon Soleq Pvt Ltd) | 8.78 | | | | | |
| Winsol solar (Polepally) | 2.58 | | | | | |
| Winsol solar (Tandur) | 8.81 | | | | | |
| Zuka Solar | 10.33 | | | | | |
| IPPs | SINAGARENI | 707.15 | | MU | in % | |
| | TOTAL INPUT | 5987.02 | Total Losses | 143.11 | 2.39 | |

* Transmission Losses are applicable to OA Users for the period from 00:00 Hrs.of 26th June- 2024 to 24:00 Hrs of 25th July - 2024

* The Transmission Losses are worked out by using MRI data.

* MRI Data considered is from 00.00 Hr of 1st May-2024 to 24.00 Hr of 31st May-2024 at 00.15 Hr interval.

* Cumulative losses at TS-Periphery FY 2024-25 is 2.36 %